



中国国家强制性产品认证证书

证书编号：2015010307760141

委托人名称、地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

生产者（制造商）名称、地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

生产企业名称、地址

ABB 新会低压开关有限公司
广东省江门市新会区今古洲工业开发区

产品名称和系列、规格、型号

电动机保护用断路器
MS165, MO165; 具体参数请见附件

产品标准和技术要求

GB/T14048. 2-2008; GB/T14048. 4-2010

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，
特发此证。

发证日期：2019 年 11 月 14 日 有效期至：2024 年 11 月 14 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2015 年 03 月 16 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2015010307760141

NAME AND ADDRESS OF THE APPLICANT

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE FACTORY

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province,
P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Motor protection circuit breaker
MS165, MO165; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008;GB/T14048.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Nov.14,2019

Valid until: Nov.14,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Mar.16,2015

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2015010307760141

纸 号: 2459023

MS165, M0165

Uimp: 8kV;

Ui: 1000V;

Ue: AC400V, AC690V;

In: 10-16A, 14-20A, 18-25A, 23-32A, 30-42A, 40-54A, 52-65A, 62-73A, 70-80A (MS165);

16A, 20A, 25A, 32A, 42A, 54A, 65, 73, 80A (M0165);

过电流脱扣器类型: 热磁式 (MS165), 电磁式 (M0165);

AC400V:

Ics=Icu=100kA (MS165-16, M0165-16, MS165-16B, M0165-16B, MS165-20, M0165-20, MS165-20B, M0165-20B, MS165-25, M0165-25, MS165-25B, M0165-25B, MS165-32, M0165-32, MS165-32B, M0165-32B);

Ics=Icu=50kA (MS165-42, M0165-42, MS165-42B, M0165-42B);

Ics=30kA, Icu=50kA (MS165-54, M0165-54, MS165-54B, M0165-54B, MS165-65, M0165-65, MS165-65B, M0165-65B);

Ics=Icu=30kA (MS165-73, M0165-73, MS165-80, M0165-80);

AC690V:

Ics=Icu=10kA (MS165-16, M0165-16, MS165-16B, M0165-16B, MS165-20, M0165-20, MS165-20B, M0165-20B, MS165-25, M0165-25, MS165-25B, M0165-25B, MS165-32, M0165-32, MS165-32B, M0165-32B, MS165-42, M0165-42, MS165-42B, M0165-42B);

Ics=6kA, Icu=8kA (MS165-54, M0165-54, MS165-54B, M0165-45B, MS165-65, M0165-65, MS165-65B, M0165-65B, MS165-73, M0165-73, MS165-80, M0165-80);

使用类别: A; AC-3;

适用频率: 50/60Hz;

适用隔离;

脱扣级别: 10;

极数: 3P

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2015010307760141

纸 号: 2459023

配用的辅助触头:

(HKF1)

I_{th}: 5A;

AC-15: U_e/I_e: 24V/3 A, 120 V/3 A, 240 V/1,5 A;

DC-13: U_e/I_e: 24V/1 A, 125V/0.27 A, 250V/0.11A;

1N01NC, 2NO;

(SK1, HK1, CK1)

I_{th}: 6A;

AC-15: U_e/I_e: 24V/6 A, 110-120 V/6 A, 220 - 240 V/4A, 400 V/3A, 690V/1A;

DC-13: U_e/I_e: 24V/2 A, 110 - 125 V/0.55A, 250 V/0.27A, 400 V/0.15A, 600 V 0.15A;

1N01NC, 2NO, 2NC

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心